


**PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION**  
**CERTIFICATE**

No. 213


Dated: 11-07-2024

It is certified that an inspection team headed by **Jahid Khan, V.D.O, Gram Panchayat** (Name of Officers with designation) from **Gram Panchayat- Bilsuri, Tehsil- Sikandrabad, District- Bulandshahr** inspected the **Maharaja Surajmal Holy Academy, Vill + Post- Bilsuri, Tehsil- Sikandrabad, District- Bulandshahr** (Name & Address of the school) on **09-07-2024** (date of inspection) and certified that the **Maharaja Surajmal Holy Academy** ( Name of school) has safe drinking water facilities for the students and members of staff of the institution. School also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid for 1 year.

Signature with Seal   
Name : Jahid Khan  
Designation : V.D.O Gram Panchayat  
Vill + Post- Bilsuri,  
District- B.S.R

To  
Maharaja Surajmal Holy Academy,  
Vill + Post- Bilsuri, Tehsil- Sikandrabad,  
District- Bulandshahr, U.P- 203205



कार्यालय अधिशासी अभियन्ता खण्ड कार्यालय  
उ०प्र० जल निगम (ग्रामीण),  
विकास भवन द्वितीय तल-336 बुलन्दशहर

पत्रांक:- ५११

/ पी-३

/ २१

दिनांक:- १०/०५/२०२५

क्र०सं०	विकास खण्ड	ग्राम पंचायत का नाम	राजस्व ग्राम का नाम	स्थल का नाम	भौतिक परीक्षण				रासायनिक परीक्षण (पी० पी० एम०)						
					पी० एच०	टी० डी० एस०	टर्बिडिटी	रंग	क्लोराईड	सम्पूर्ण कठोरता	एल्कालिनिटी	आयरन	नाइट्रेट	फ्लोराइड	जीवाणु
					6.5-8.5	500-2000	0-5		250-1000	200-600	200-600	0.3-1.0	0-45	1-1.5	0.01-0.05
1	बुलन्दशहर	बिलसूरी	बिलसूरी	महाराजा सूरजमल होली अकैडमी	7.35	608	0.43	रंगहीन	56	332	464	0.10	10.0	0.5	0.0

Lab Chemist

JE (Lab)

AE (Lab)